

Jerome Newton, Mayor

Commissioners

Barbara Kornegay

Mayor Pro Tempore

Vicky Darden

Delreese Simmons

Danny Keel

Tommy Brown



Tel – 919-658-5561

Tel – 919-658-9539

Glenn Holland

Interim Town Manager

Sherry Davis

Town Clerk

October 16, 2025

Quarterly Report Summary

TOWN OF MOUNT OLIVE WASTEWATER TREATMENT PLANT EMC SOC WQ S20-0021

Reporting Period: July, August & September 2025

WQCS00129 - COLLECTIONS

Report on Progress Made Under SOC Requirements

The sewer collections department has completed CCTV Inspections and Line Cleaning of 11,140 linear feet. This is part of the 34,000 linear feet required to be completed by January 31, 2026. A total of 41 manholes were inspected this month as part of the ongoing sewer system assessment program. Routine lift station inspections and maintenance continued throughout the month with no major disruptions to operations.

Item 12 Appendix B of the AIA is required to be completed by October 31, 2025, Due to the total project coming in over budget this deadline cannot be met. The engineers are working to change the scope of work in order to move forward with the project. The town will submit an update to the NC DEQ under separate cover regarding the projected completion date.

Item 13 The inspection identified the need for one repair to McPhail Blvd. (~250 LF).


Item 14 Address the repair of McPhail Blvd, which was due July 31, 2025, has not been completed. The town is determining manner of repair required and funding source. The town has been in communication with NC DEQ and will submit an update under separate cover regarding the projected completion date.

The Town self-reported a violation of the flow moratorium to the Division of Water Resources in July 2025. The Town took the following corrective actions to prevent further violations:

- The Town met with the Wayne County Permitting Department to facilitate communication and clarify the permitting process with the county.
- Mount Olive Permitting Department: Personnel received training to qualify the town to self-perform permitting. 2T rules and their application to permitting and zoning decisions were reviewed with town permitting personnel.
- A presentation regarding the flow moratorium, 2T rules, and the process for using the 2T rules when deciding zoning issues was provided to the Mayor and Board of Commissioners in August 2025.
- The Town has drafted Like-for-Like and Abandoned Property policies. These are under review and will be presented to the Mayor and Board for approval in 2026.

Report on Expected Progress In the October, November & December 2025 Quarter

The sewer collections department will continue to prioritize CCTV inspections and cleaning to stay ahead of the required schedules for future Special Order of Consent reporting, plans to move into the third twenty percent phase of CCTV inspections and cleaning and will continue working toward completing the Appendix B section of the Special Order of Consent.

Sincerely,

Glenn Holland
Interim Town Manager